



नवी मुंबई
महानगरपालिका

Navi Mumbai
Municipal Corporation

पर्यावरण प्रयोगशाळा
अग्रोळी पुलाखाली, सी.बी.डी. बेलापूर, नवी मुंबई 400 614.
दुरध्वनी क्र. : 2757 9882



NMMC/Environment Laboratory/36/2022-2023

Date : 16/12/2022

Date of sample received. : 16/12/2022

Date of sample testing : 16/12/2022 to 19/12/2022

Customer's Name and Location : MES Vidya Mandir
Sec - 21/22, CBD , Belapur
Navi Mumbai 400 614

TEST REPORT

| Sr. No. | Testing Parameter | Test Result | Test Standards (IS 10500 : 2012) |
|---------|----------------------|-------------|---------------------------------------|
| 01 | pH | 7.1 | 6.5 - 8.5 |
| 02 | Turbidity | 0.0 | Max. 5.0 N.T.U. |
| 03 | Residual Chlorine | 0.1 | Min. 0.2 mg/l |
| 04 | Bacteriological Test | | |
| | Total Coliforms | 0 | 0 per 100 ml |
| | E. Coli | - ve | - ve |
| | F. Coli | - ve | - ve |

Test Report No. : 36

Date : 19/12/2022

Conclusion : Test results of the sample are based on the sample submitted in the laboratory.

Lab Incharge

Lab Chemist

Environment Laboratory
Navi Mumbai Municipal Corporation



**नवी मुंबई
महानगरपालिका**

मुख्यालय से.१५ ए, किल्ले गावठाण जवळ,
सौ.बी.डी. बेलापूर, नवी मुंबई - ४०० ६१४
दुरध्वनी क्रमांक: २७५६ ७०७०
२७५६ ५७००

**Navi Mumbai
Municipal Corporation**

Head Quarter, Sec. 15 A, near kille Gaonthan,
CBD., Navi Mumbai- 400 614
TEL.No. : 2756 7070
2756 5700

No.NMMC/SWM/820/2022

Date: - 11/08/2022.

To WHOMSOEVER IT MAY CONCERN

This is to certify tha Navi Mumbai Municipal Corporation's sanitary officer has inspected at Maharashtra Education Society's Vidya Mandir Sector 21/22, C.B.D. Belapur Navi Mumbai. On dated.05.08.2017 from the sanitary point of view. The aforesaid premises is found to be satisfactory and hence this certificate is signed and issued for office use only.This Certificate is issued as per Head Master, Viday Mandir request letter.

Bajale
11/8/22

(Babasaheb Rajale)

**Dy.Municipal Commissioner
Solid Waste Management Dept.
Navi Mumbai Municipal Corporation**